

Record Sheet for F-Gas Regulation			
Plant Owner/Operator:	Mason & Pinder Toolmakers Coulman St, Thorne, Doncaster DN8 5JU		
Site Phone Number:	01709 770000		
Site Contact: Chris Wareham	Direct Number: 03443 759553		
Location of Plant Outdoor: Side of building	Indoor: Chris Wareham's office		
Plant Name/Ref: Unit 1	Serial: E001123		
Manufacturer: Fujitsu	Model: AOYR18LEC		
Refrigerant Type: R410A	Quantity (kg) 1.20		
Installer: Unknown	Date Installed: UNKNOWN		
Refrigerant Additions			
Date	Company/Technician	Amount	Reason
18/04/2018	2A Services / A.Job	1.200 KG	Re charge following repair
Refrigerant Removal and Disposal Information			
Date	Company/Technician	Amount	Reason/destination of disposal
18/04/2018	2A Services / A.Job	1.030 KG	Leak Found / Climate Centre
Leak Tests / Services			
Date	Company/Technician	Test Result	Action Required / Notes
02/03/2018	2A Services / A.Job	FAIL	Find leak and repair
18/04/2018	2A Services / A.Job	PASS	NONE
21/09/2018	2A Services / A.Job	PASS	NONE
Follow-up Action			
Date	Company/Technician	From Date	Action Taken
Automatic Leak Detection System Test (If fitted)			
Date	Company/Technician	Test Result	Comments